

## Public Record Summary Information on Underground Storage Tanks (USTs) From 10/1/2015 To 9/30/2016 General Information

Total Number of Active UST Facilities: 5,287

Total Number of Active UST Compartments: 16,300

### Summary Information For On-Site Inspections

Number of UST Facilities Inspected: 2,194

Inspection Period: 10/1/2015 To 9/30/2016

Percent Compliance

Release Prevention: 85.52%

Release Detection: 85.97%

Combined Compliance: 76.87%

Note: Tanks, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs and those deferred in 40 CFR 280.10(c). On-site inspections measure compliance with release detection and release prevention (significant operational compliance, state regulations, Subtitle I, etc.).

### Summary Information For Releases

Number of Confirmed UST Releases: 162

Release Reporting Period: 10/1/2015 To 9/30/2016

### Summary Information For Release Sources and Causes

Source/Location			Cause																
			Not Listed		Spill		Overfill		Corrosion		Install Problems		Phys/Mech Damage		Unknown		Other		
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Not Listed	45	27.8%	42	93.3%										2	4.4%	1	2.2%		
Delivery Problem		0.0%																	
Dispenser	3	1.9%														3	100.0%		
Other	3	1.9%	3	100.0%															
Overfill		0.0%																	
Piping	12	7.4%												12	100.0%				
STP	1	0.6%												1	100.0%				
Tank	7	4.3%														7	100.0%		
Unknown	91	56.2%												4	4.4%	86	94.5%	1	1.1%
<b>Total</b>	<b>162</b>	<b>100.0%</b>	<b>45</b>	<b>27.8%</b>										<b>19</b>	<b>11.7%</b>	<b>97</b>	<b>59.9%</b>	<b>1</b>	<b>0.6%</b>

Note: Release, source, and cause information is based on underground storage tanks regulated under subtitle I that satisfy the definition of UST in 40 CFR 280.12. This report reflects data from releases reported to the Department during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities.

Additional information on site-specific USTs such as compliance releases may be obtained through contacting the Tennessee Division of Underground Storage Tanks at 615-532-0945.