



STATE OF TENNESSEE
DEPARTMENT OF COMMERCE AND INSURANCE
DIVISION OF FIRE PREVENTION
ADMINISTRATIVE SERVICES SECTION
PERMITS AND LICENSES UNIT
500 JAMES ROBERTSON PARKWAY
NASHVILLE, TENNESSEE 37243
TELEPHONE: 615-741-1322 FAX: 615-741-1583

REGULATIONS FOR SEASONAL FIREWORKS SALES

(These items are not all encompassing. Please refer to applicable laws, rules, and codes for additional requirements)

1. Only consumer fireworks (1.4G) may be sold. Illegal fireworks will be confiscated by the State Fire Marshal. [Tenn. Code Ann. § 68-104-108, and 68-104-115]
2. Fireworks must be stored at least 10 feet away from windows where the sun may shine through. [Tenn. Code Ann. § 68-104-111]
3. A "FIREWORKS-NO SMOKING" sign, with letters not less than 4 inches high, must be posted and visible. Smoking must not be permitted within 10 feet of fireworks. [Tenn. Code Ann. § 68-104-111]
4. The state license must be accurate for the site location and be posted in a conspicuous place. [Tenn. Code Ann. § 68-104-102 (c)]
5. Extension cords and wiring, when used outdoors, must be listed for wet locations, and be protected against physical damage. [2008 NFPA 70, 525-20 (A)]
6. Ground fault interrupter protection must be used for power cords that supply power to tents and other outside locations. [2008 NFPA 70, 525-23]
7. Electrical wiring inside tents and other outdoor locations shall be securely installed, without splices, and lamps shall be protected from accidental breakage by a suitable fixture or guard. [2008 NFPA 70, 525-21 (B)]
8. Combustible materials must be kept at least 30 feet from fireworks. [2006 NFPA 1124, 7.4.6.1]
9. Heating devices must be listed and used in accordance with their listings. Temporary heating shall have overheat and tip-over protection devices. [2006 NFPA 1124, 7.3.17.2]
10. Seasonal retailers must have at least one portable fire extinguisher within 35 feet of any point in the tent/building. [2006 NFPA 1124, 7.4.5.2]
11. At least one fire extinguisher must be of the multipurpose dry chemical type if the facility has electrical power. [2006 NFPA 1124, 7.3.8.2]
12. The facility and fireworks must be located at least 50 feet from retail propane dispensing stations, aboveground storage tanks for flammable or combustible liquids or gas, and motor vehicle fuel dispensers. The facility and fireworks must be at least 300 feet from bulk flammable or combustible liquid or gas storage. [2006 NFPA 1124, 7.3.12.2, and 7.3.12.6]



**STATE OF TENNESSEE
DEPARTMENT OF COMMERCE & INSURANCE
DIVISION OF FIRE PREVENTION
ADMINISTRATIVE SERVICES SECTION
PERMITS AND LICENSING UNIT
500 JAMES ROBERTSON PARKWAY
DAVY CROCKETT TOWER
NASHVILLE, TN 37243-1159
(615)-741-1322 – 615-741-1583 (Fax)**

APPLICATION FOR SEASONAL RETAILER FIREWORKS PERMIT

(Pursuant to Title 68, Chapter 104, Tennessee Code Annotated)

Permit fee: \$100.00

Checks or money orders should be made payable to the Department of Commerce and Insurance.

Print or type all information. All fields must be completed before the application will be processed. An incomplete application will delay issuance of the permit.

Name of Firm _____

Mailing Address _____

City _____ State _____ Zip _____ Telephone # () _____

Fax # () _____

Name of Owner _____ Date of Birth ____/____/____

Social Security # _____ Telephone # () _____

LOCATION OF BUSINESS

Address _____ Telephone # () _____

City _____ Zip Code _____ County _____

Will fireworks be located at this location year round? Yes ____ No ____

Is there any other business conducted at this location? Yes ____ No ____ If yes, what kind of business? _____

Will gasoline, paints, oils, or other flammable or combustible substances be sold or stored that create an undue hazard to any person or property? Yes ____ No ____

