

Contract	Age	Cylinder	LBF	PSI	Area	P/F	Design	Required	Made	Tested	Fracture
T336	31	741	74813	5950	12.566	Pass	230668	3000	12/22/2023	1/22/2024	Cone
T336	31	741A	74040	5890	12.566	Pass	230668	3000	12/22/2023	1/22/2024	Cone
X139	31	4A	75401	6000	12.566	Pass		3000	12/22/2023	1/22/2024	Columnar
X139	31	4A	77175	6140	12.566	Pass		3000	12/22/2023	1/22/2024	Cone & Shear
U922	32	308A	60862	4840	12.566	Pass	230159	3000	12/21/2023	1/22/2024	Cone
U922	32	308A	60648	4830	12.566	Pass	230159	3000	12/21/2023	1/22/2024	Columnar
DB2101	32	44A	49111	3910	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Shear
DB2101	32	44A	48536	3860	12.566	Pass		3000	12/21/2023	1/22/2024	Columnar
X206	32	3A	74376	5920	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Split
X206	32	3A	69883	5560	12.566	Pass		3000	12/21/2023	1/22/2024	Cone
X129	32	1A	58052	4620	12.566	Pass	230976	3000	12/21/2023	1/22/2024	Cone
X129	32	1A	54890	4370	12.566	Pass	230976	3000	12/21/2023	1/22/2024	Columnar
X119	32	46A	66563	5300	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Shear
X119	32	46A	67675	5390	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Shear
V300	32	17ARK	164973	13130	12.566	Pass		10000	12/21/2023	1/22/2024	Cone
V300	32	17ARK	161243	12830	12.566	Pass		10000	12/21/2023	1/22/2024	Cone
V281	32	701	71453	5690	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	701A	80136	6380	12.566	Pass		4000	12/21/2023	1/22/2024	Cone & Shear
V281	32	700	79375	6320	12.566	Pass		4000	12/21/2023	1/22/2024	Cone & Shear
V281	32	700A	73547	5850	12.566	Pass		4000	12/21/2023	1/22/2024	Cone & Split
V281	32	699	80110	6370	12.566	Pass		4000	12/21/2023	1/22/2024	<None>
V281	32	699A	79830	6350	12.566	Pass		4000	12/21/2023	1/22/2024	Cone
V281	32	698	73997	5890	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	698A	92856	7390	12.566	Pass		4000	12/21/2023	1/22/2024	Cone & Shear
V281	32	697	78443	6240	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	697A	89421	7120	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	696	101027	8040	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	696A	97842	7790	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	695	84310	6710	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	695A	84391	6720	12.566	Pass		4000	12/21/2023	1/22/2024	Cone
V281	32	694	96629	7690	12.566	Pass		4000	12/21/2023	1/22/2024	Cone & Shear

V281	32	694A	101161	8050	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
V281	32	693	113113	9000	12.566	Pass		4000	12/21/2023	1/22/2024	Cone
V281	32	693A	106471	8470	12.566	Pass		4000	12/21/2023	1/22/2024	Columnar
U367	32	80A	62337	4960	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Shear
U367	32	80A	62226	4950	12.566	Pass		3000	12/21/2023	1/22/2024	Cone & Shear
CPI	32	137V	183418	14600	12.566	Pass		10000	12/21/2023	1/22/2024	Cone
CPI	32	137V	186216	14820	12.566	Pass		10000	12/21/2023	1/22/2024	Cone
CPI	32	177V	153168	12190	12.566	Pass		10000	12/21/2023	1/22/2024	Cone & Shear
CPI	32	177V	157472	12530	12.566	Pass		10000	12/21/2023	1/22/2024	Columnar
CPI	32	176V	167129	13300	12.566	Pass		10000	12/21/2023	1/22/2024	Cone
CPI	32	176V	166594	13260	12.566	Pass		10000	12/21/2023	1/22/2024	Columnar
X135	32	1	67516	5370	12.566	Pass	231101	3000	12/21/2023	1/22/2024	Columnar
X135	32	1A	69477	5530	12.566	Pass	231101	3000	12/21/2023	1/22/2024	Cone
W055	32	304A	87559	6970	12.566	Pass	230586	3000	12/21/2023	1/22/2024	Cone & Shear
W055	32	304A	87006	6920	12.566	Pass	230586	3000	12/21/2023	1/22/2024	Cone
V012	32	131	53969	4290	12.566	Pass		3000	12/21/2023	1/22/2024	Columnar
V012	32	131A	55308	4400	12.566	Pass		3000	12/21/2023	1/22/2024	Columnar
U032	32	434A	80070	6370	12.566	Pass	230984	3000	12/21/2023	1/22/2024	Cone & Split
U032	32	434A	82830	6590	12.566	Pass	230984	3000	12/21/2023	1/22/2024	Cone
T925	32	219	65918	5250	12.566	Pass	230034	3000	12/21/2023	1/22/2024	Cone & Shear
T925	32	219A	63196	5030	12.566	Pass	230034	3000	12/21/2023	1/22/2024	Cone & Shear
T336	32	739	55010	4420	12.441	Pass	230668	3000	12/21/2023	1/22/2024	Columnar
T336	32	739A	56849	4520	12.566	Pass	230668	3000	12/21/2023	1/22/2024	Cone & Shear
120012	32	22A	69717	5600	12.441	Pass	230029	3000	12/21/2023	1/22/2024	Columnar
120012	32	22B	72687	5780	12.566	Pass	230029	3000	12/21/2023	1/22/2024	Columnar
DB2101	33	43A	54511	4340	12.566	Pass		3000	12/21/2023	1/23/2024	Columnar
DB2101	33	43A	59222	4710	12.566	Pass		3000	12/21/2023	1/23/2024	Columnar
V010	28	75	62916	5030	12.504	Pass		3000	12/26/2023	1/23/2024	Cone
V010	28	75A	64622	5140	12.566	Pass		3000	12/26/2023	1/23/2024	Columnar
T925	28	218A	72566	5830	12.441	Pass		3000	12/26/2023	1/23/2024	Cone
T925	28	218A	73041	5810	12.566	Pass		3000	12/26/2023	1/23/2024	Cone & Shear
X323	34	2A	64828	5160	12.566	Pass		3000	12/21/2023	1/24/2024	Cone & Shear

X323	34	2A	63776	5080	12.566	Pass		3000	12/21/2023	1/24/2024	Cone & Shear
DB2101	28	45A	36739	< 2920	12.566	Fail		3000	12/27/2023	1/24/2024	Cone & Shear
DB2101	28	45A	43749	3480	12.566	Pass		3000	12/27/2023	1/24/2024	Cone & Shear
CPI	28	16V	155132	12350	12.566	Pass		10000	12/27/2023	1/24/2024	Cone & Shear
CPI	28	16V	168209	13390	12.566	Pass		10000	12/27/2023	1/24/2024	Cone
V914	28	70A	57564	4560	12.629	Pass		3000	12/27/2023	1/24/2024	Cone & Split
V914	28	70A	56752	4520	12.566	Pass		3000	12/27/2023	1/24/2024	Cone & Shear
X285	28	6A	68404	5440	12.566	Pass	BAG MIX	3000	12/27/2023	1/24/2024	Columnar
X285	28	6A	64375	5120	12.566	Pass	BAG MIX	3000	12/27/2023	1/24/2024	Cone & Shear
X285	28	5A	71198	5640	12.629	Pass	BAG MIX	3000	12/27/2023	1/24/2024	Columnar
X285	28	5A	70884	5640	12.566	Pass	BAG MIX	3000	12/27/2023	1/24/2024	Cone & Shear
121995	28	20A	61457	4940	12.441	Pass	650025	3000	12/27/2023	1/24/2024	Cone & Shear
121995	28	20A	62625	4980	12.566	Pass	650025	3000	12/27/2023	1/24/2024	Cone
W383	35	13A	117860	9380	12.566	Pass		3000	12/21/2023	1/25/2024	Cone & Shear
W383	35	13A	110451	8790	12.566	Pass		3000	12/21/2023	1/25/2024	Cone & Split
W383	36	12A	97378	7750	12.566	Pass		3000	12/20/2023	1/25/2024	Cone
W383	36	12A	102819	8180	12.566	Pass		3000	12/20/2023	1/25/2024	Cone
W386	28	9A	135347	5000	27.062	Pass		3000	12/28/2023	1/25/2024	Cone & Shear
W386	28	9A	129629	4580	28.274	Pass		3000	12/28/2023	1/25/2024	Cone
V010	28	76	66107	5290	12.504	Pass	230037	3000	12/28/2023	1/25/2024	Columnar
V010	28	76A	63451	5050	12.566	Pass	230037	3000	12/28/2023	1/25/2024	Columnar
X229	28	90V	142530	11460	12.441	Pass		10000	12/28/2023	1/25/2024	Cone & Shear
X229	28	90V	151024	12020	12.566	Pass		10000	12/28/2023	1/25/2024	Cone
X229	28	88V	143394	11530	12.441	Pass		10000	12/28/2023	1/25/2024	Cone
X229	28	88V	160237	12750	12.566	Pass		10000	12/28/2023	1/25/2024	Columnar
X229	28	89V	148351	11920	12.441	Pass		10000	12/28/2023	1/25/2024	Cone
X229	28	89V	155764	12400	12.566	Pass		10000	12/28/2023	1/25/2024	Cone
U922	15	582B	84135	6700	12.566	Pass	240043	4500	1/11/2024	1/26/2024	Cone & Shear
U922	15A	582B	75907	6040	12.566	Pass	240043	4500	1/11/2024	1/26/2024	Columnar
U922	15	581B	86047	6850	12.566	Pass	240043	4500	1/11/2024	1/26/2024	Columnar
U922	15	581B	76662	6100	12.566	Pass	240043	4500	1/11/2024	1/26/2024	Cone & Shear
W181	1	75B	19261	< 1530	12.566	Fail	240078	3000	1/25/2024	1/26/2024	Cone

W181	1	75C	18929	< 1510	12.566	Fail	240078	3000	1/25/2024	1/26/2024	Cone
CPI	28	17V	154171	12270	12.566	Pass		10000	12/29/2023	1/26/2024	Cone
CPI	28	17V	154871	12320	12.566	Pass		10000	12/29/2023	1/26/2024	Cone & Shear
CPI	28	138V	191475	15240	12.566	Pass		10000	12/29/2023	1/26/2024	Cone & Shear
CPI	28	138V	179373	14270	12.566	Pass		10000	12/29/2023	1/26/2024	Cone