



STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION

**INVITATION TO BID # 32701-13277  
AMENDMENT # 1  
FOR HENRY HORTON GREENWAY TRAIL**

DATE: April 10, 2024

ITB # 32701-13277 IS AMENDED AS FOLLOWS:

1. This ITB Schedule of Events updates and confirms scheduled ITB dates. Any event, time, or date containing revised or new text is highlighted.

Event	Time	Due Date
Event Posted	8:00 am CT	3-26-2024
Questions and Comments Due	4:30 pm CT	4-3-2024
Bids Due	2:00 pm CT	4-16-2024

2. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		Scope – Flexible Porous Pavement – There are several types of flexible porous pavement systems but the Specification goes on to list a whole series of requirements (item 1, subitems e – m in the Specification). So on the surface, the Park seems to know exactly what kind of porous pavement systems they looking for...can the State name the specific product/brand they are seeking? In particular the use of reclaimed rubber and meeting ADA?	No, we cannot provide a specific brand, all standards should be for slip resistance and firmness.
		Scope – ADA Compliance – Items 6 indicates ADA compliance and also indicates “All”. We like this project because of the ADA requirements but we want to verify that the Park is requesting full ADA compliance?	The project should be ADA accessible but does not need to be 100% compliant in its entire length. We identified some ADA challenges on the map and on-site at the pre-bid meeting.

3. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.