

## ADDENDUM #2

**Date:** May 24, 2016  
**Project No.** 08166-1  
**Project Name:** Eastgate Greenway, Phase 2 (PIN 114946.01); Sevierville, Tennessee

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the Contract Documents for the above-referenced project.

Failure to acknowledge this addendum in the Bid Form may result in the Bid being deemed non-responsive.

Where any original item is amended, voided, or superseded hereby, the provision of such item not so specifically amended, voided, or superseded shall remain in effect.

### **NARRATIVE:**

#### Clarifications

1. The bid deadline has been revised:
  - a. Sealed Bids for shall be received by: Tracy Baker-Purchasing Agent/Assistant City Administrator of the City of Sevierville, 120 Gary Wade Blvd., Sevierville, TN 37862, (Mailing Address: Tracy Baker-Purchasing Agent/City of Sevierville, Tennessee/P.O. Box 5500, Sevierville, Tennessee 37864-5500) until **3:00 PM EST, June 1, 2016** and opened publicly in the Downstairs Conference Room, at that hour. The reading of the bids will begin at 3:01 PM EST.
2. The City of Sevierville will waive all local permitting fees.
3. Bid questions will be accepted until **May 26, 2016, 2:00 PM CST.**

#### Project Drawing Revisions

1. Detail 3 on Sheet C4.01 has been revised to indicate a concrete pier in the plan view. It has also been revised to indicate a concrete pier depth as recommended by the professional engineer sealing the requested shop drawings.

#### Project Specification Revisions

1. None.

#### Received Bidder Questions

1. *How is geotextile to be installed below the pathway?*
  - a. Geotextile is not part of the pathway design (see Detail 3 and Detail 4 on Sheet C4.00).
2. *Is the ramp utilizing round piles or concrete piers? How deep are the piles/piers?*
  - a. The ramp shall utilize concrete piers. Pier depth shall be as recommended by professional engineer sealing the requested shop drawings.

#### Substitution Requests – APPROVED

1. None.

#### Substitution Requests – DENIED

1. None.

*(continued with Attachments)*

Attachments

1. Pre-Bid Sign-In Sheet – 1 page
2. Sheet C4.01 – 1 page

NOTE: Receipt of this Addendum must be acknowledged on the Bid Form.

END OF ADDENDUM



